

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203284
Address: 4417 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Patrick Schonfeldt	Failed	Wednesday, March 03, 2021

Corrective Action Required:

1	DCM1 ESC REQUIRED NO FURTHER INSP	EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE. -RE ESTABLISH AND MAINTAIN EROSION CONTROL SILT FENCE ON NEIGHBORING LOTS OF HOUSE AND ALONG BACK OF LOT AT WOODED CREEK AREA -CLEAN ALL CONSTRUCTION DEBRIS THAT HAS BLOWN OFF SITE ONTO NEIGHBORING LOTS AND AT BACK OF WOODED AREA
---	---	--

Comments: