

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203286
Address: 4528 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Patrick Schonfeldt	Failed	Wednesday, March 03, 2021

Corrective Action Required:

1	Misc	-WATER BOND REQUIRED, SURFACE SHALL BE CORROSION RESISTANT CONDUCTIVE SURFACE THAT EXPOSES NOT LESS THAN 9 SQ INCHES. NEC 680.28 (C)
---	------	--

Comments: