

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203771
Address: 4509 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Patrick Schonfeldt	Failed	Wednesday, March 03, 2021

Corrective Action Required:

1	Misc	-POOL BONDING INCOMPLETE AT TIME OF INSPECTION. COMPLETE PERIMETER SURFACE BOND (4) POINTS UNIFORMLY SPACED, CONDUCTIVE SHELL BOND, WATER BOND, POOL PUMP BOND NEC 680.26
---	------	---

Comments: