

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20203581  
Address: 4068 NE TIMBERLAKE CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Khanh Nguyen	Partial	Wednesday, March 03, 2021

Corrective Action Required:

1	Misc	THE NORTH PIER IS FULL OF WATER. PUMP OUT WATER AND REMOVE CAVED-IN DIRT.
		OK TO POUR THE OTHER PIERS

**Comments:**