

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200811

Address: 3561 SW MARKET ST, Unit:IR, LEES SUMMIT, MO 640823561 SW MARKET ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Engineering</b>	Tom Taylor	Failed	Thursday, March 04, 2021

Corrective Action Required:

1	Misc	Need as-builts for detention basin in order to receive TCO. Contractor has been notified of this requirment.
---	------	--

**Comments:**