CITY OF LEE'S SUMMIT **Development Services Department** 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204977

Address: 202 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Footing Inspection - Residential Michael Harkins Failed Thursday, March 04,

2021

Partial Correction:

Misc - PARTIAL PASS -1

- SUBMIT ENGINEERS SOIL REPORT & COMPACTION REPORT FOR AB3 IN 8"

LIFTS -

- INSULATE FROST FOOTINGS ON AB-3 -

Corrective Action Required:

Miscellaneous

- DIG DOWN AND PROVIDE FROST PROTECTION ON WALKOUT PORTION OF Correction THE FOUNDATION AS PER DISCUSSIONON SITE WITH DAN BROMLEY AND

JASON. -

- PROVIDE THE ENGINEERS REPORT ON 8

'LIFTS-

Comments: