

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210054
Address: 206 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Michael Harkins	Passed	Thursday, March 04, 2021

Informational:

1 Misc

- 3RD PARTY PIERS BY BOB ROWE @ VAN DEURZEN
SIGNED & SEALED BY CHAD STREETER -
- (3) 24" X 3'0" BEARING CLAY -
- APPROVED BASEMENT & GARAGE SLABS AND APPROVED DECK PIERS -

Comments: