

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20204497  
Address: 111 SE M 291 HWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Khanh Nguyen	Failed	Thursday, March 04, 2021

**Corrective Action Required:**

1	Misc	-Install boca plates at bottom track for extra 2" of plumbing protection -Secure 2" or smaller pvc at mid-wall -Secure MC cable within 12" of boxes -Install bonding pigtail for bonding devices
---	------	---

**Comments:**