

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20200811

Address: 3561 SW MARKET ST, Unit:IR, LEES SUMMIT, MO 64082  
3561 SW MARKET ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Patrick Schonfeldt	Failed	Thursday, March 04, 2021

Corrective Action Required:

1	Misc	-PARKING LIGHT POLE GROUND ROD CONNECTION -SPARK RINGS AT RECEPTACLES ON ALL COMBUSTIBLE SURFACES NOT FLUSH WITH SURFACE -BOND AT WATER LINE ACROSS FROM BACKFLOW VALVE -COMPLETE BOX/CONDUIT INSTALLATION AT SALES FLOOR, SOUTH WALL -GFCI RECEPTACLE AT CUSTOMER SALES FLOOR BATHROOM NOT TRIPPING WHEN TESTED
---	------	--

Comments: