

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20203513  
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Michael Harkins	Partial	Thursday, March 04, 2021

Informational:

1	THE FOLLOWING AREAS ARE APPROVED	: PRESS BOX : - NORTH END DETAIL 10 S200 ELEVATOR PIT - - RESTROOMS LINE K TO P / LINE 7 TO 9 UFER EAST FOOTING AT MECHANICAL ROOM - - RESTROOMS FOOTING COMPLETE OK TO POUR- - CONCESSION STAND SE END NOT DUG OK TO POUR 3 SIDES, UFER IN SW FOOTING -
---	----------------------------------	--

**Comments:**