



February 4, 2021

Cardinal Crest

Re: 1036 SW Armie Road
Pergola Park, Lot 94
Permit #: PRRES20203659

Apex Engineers, Inc. observed the preparations of the garage and front stoop slabs for the proposed house located at the above referenced address.

The two slabs will be structural with a gravel base course. The forms and reinforcing steel were found to be clean, well aligned, properly supported and in compliance with the design.

Note:

- The inspections were performed at 2:00 pm
- Flashing was installed in the stoop.
- At the time of the inspection the temperature was 63°
- Erosion control was installed at the time of inspection.

Our firm recommends approval of the front stoop and garage slabs for the placement of concrete. This report does not constitute approval by the enforcing jurisdiction.

LIMITATIONS

The recommendations and conclusions given in this report are based on the observed conditions at the time of this site visit. The scope of our services was only to observe the installation of the slab formwork and reinforcing steel. If changes in the condition of the site occur and Apex Engineers, Inc. is not allowed the opportunity to re-evaluate the site to respond to any of these changes, our firm cannot be responsible for the effect of any of the conditions that differed from those reported herein.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,
Apex Engineers, Inc.

Kevin Miller
Engineering Technician

Clayton J. Hess,
Principal

