

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210283  
Address: 317 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Michael Harkins	Partial	Tuesday, March 09, 2021

Corrective Action Required:

1	Misc	- PROVIDE GEOTECHNICAL ENGINEER'S REPORT VERIFYING 2000 PSF BEARING S-3.1 - - UFER FOUNDATION WALL REAR OF GARAGE -
---	------	--

**Comments:**