

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210754
Address: 337 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Michael Harkins	Failed	Tuesday, March 09, 2021

Corrective Action Required:

1	Misc	- ALL REINFORCEMENT SHALL BE LAPPED A MIN OF 24" AT ENDS SPLICES AND AROUND CORNERS (NEAR UFER 16") - -CHAIR UP #4 AT STEPDOWN FRONT OF GARAGE NEAR FRONT STOOP - - UFER NORTH FOUNDATION WALL BEHIND GARAGE -
---	------	---

Comments: