

March 5, 2021

Schwerdt Design Group, Inc.
Attn: Mike Hampton
2231 SW Wanamaker Rd, Ste # 303
Topeka, KS 66614


RE: AT&T – Lee’s Summit – Chiller Replacement
Response to City’s plan review comments
AT&T PN A01KYNV
SDG PN 190102

Mike,

This letter is to address the first item from the City of Lee’s Summit’s Building Plan Review, dated February 2, 2020. They are seeking verification that the new chiller that is proposed to replace one of the existing chillers weighs less than the existing unit. This is indeed the case. Per the placard on the existing unit, it weighs 2450lbs. Likewise, the mechanical drawings lists the operating weight of the new unit at 2136lbs.

Please let us know if anything further is needed regarding this issue.

Sincerely,


Toby Taggart, PE KS 16809


Kevin Vollrath, PE MO 2005011704

