

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204075
Address: 1920 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Residential	John Morris	Failed	Wednesday, March 10, 2021

Corrective Action Required:

1	Misc	-two bottom plates per plan 1/S4.0 -two rows of 16D sinker nails 3" OC at braced wall panel top plates per plan, see section view of detail 1/S4.0
---	------	---

Comments: