

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204715
Address: 1820 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	John Morris	Failed	Wednesday, March 10, 2021

Corrective Action Required:

1	Misc	Immediate street cleanup required, no further inspections until resolved
---	------	--

Corrective Action Required:

2	Misc	Noncompliance with erosion control inspection report dated 03/02/2021
---	------	---

- Erosion control requires continuous maintenance. Re-establish removed section at curb within 48 hours
- immediate street cleanup required
- provide and maintain gravel filter
- no further inspections until issues are resolved

Comments: