

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202913
Address: 132 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	John Morris	Failed	Wednesday, March 10, 2021

Corrective Action Required:

1	Misc	-Erosion control requires continuous maintenance. Repair damaged sections within two business days -immediate street cleanup required -no further inspections until issues are resolved
---	------	---

Comments: