



PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #:PRPWRW20210222, Public Works Right of Way Permit
Address: 1125 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit Inspection	Bob Burns	Partial	Wednesday, March 10, 2021

Corrective Action Required

1 Misc

Site visit: At 1:30 pm today the crews were onsite, I drove both north and south on Douglas through the traffic control. There was advanced warning signs in place and cones setup to close off the lanes of traffic on both sides of Douglas.

Corrective Action Required

2 Misc

The crew was onsite pouring concrete. They were using a 3k limestone mix. I rejected the concrete and told them that they needed to use the KCMMB4k mix..

Comments: