

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20202233  
Address: 470 NW CHIPMAN RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Michael Harkins	Failed	Thursday, March 11, 2021

Corrective Action Required:

1	Miscellaneous Correction	- PATCH ALL OPENINGS TO MATCH ADJACENT CONSTRUCTION IN BOTH MATERIALS & FINISH - - FIRE CAULK PENETRATIONS-
---	--------------------------	--

**Comments:**