

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20200275  
Address: 4400 SW NAUTILUS PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Patrick Schonfeldt	Failed	Thursday, March 11, 2021

Corrective Action Required:

1	Misc	-FINAL SOD AND GRADE AT MANHOLE IN FRONT YARD, ENSURE MANHOLE IS ACCESSIBLE AND AT FINISHED GRADE, ENSURE DRAINAGE PER APPROVED PLOT PLAN
---	------	-------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**