

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20204993
Address: 180 NW OLDHAM PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Thursday, March 11, 2021

Corrective Action Required:

1	Misc	- secure all vertical DWV 2" or smaller at midpoint - - provide boca plates at mop sink , vtr restrooms - - secure j boxes - - seal all penetrations in fire walls & fire caulk to underside of deck - -'provide cover plates open j boxes -
---	------	--

Comments: