

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203754
Address: 1504 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Friday, March 12, 2021

Corrective Action Required:

1	Misc	-12" oc nailing at all intersecting and abutting walls (braced walls) -fireblock at DWV vertical chase top at garage -(4) stud pack at all girder truss bearing ends per plans - see 2nd floor girders -Provide anchor bolt within 12" of plate break near gas line -Nail all exterior sheathing per plans
---	------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: