

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202309
Address: 1717 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Suspended Slab Inspection	John Morris	Failed	Monday, March 15, 2021

Corrective Action Required:

1	Misc	unable to verify header detail 5/S2.0 at 6' foundation opening rear of structure due to foundation walls being poured prior to inspection of this detail
---	------	--

Comments: