

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211096
Address: 1504 SW GEORGETOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, March 16, 2021

Corrective Action Required:

1	Misc	-FIREBLOCK BETWEEN TOP PLATE AND FOUNDATION WALL THROUGHOUT -NAIL PROTECTION PLATES AT ALL NM (ROMEX) WITHIN 1 1/4" OF END OF STUD -FIREBLOCK VERTICAL TO HORIZONTAL AT FURRED DOWN SOFFIT ENDS -BOCCA PROTECTION PLATE AT TOP AND BOTTOM PLATE DWV N WALL -COMPLETE DWV VENT IN BATH
---	------	---

Comments: