

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20201062
Address: 1804 SW RIVER RUN DR, LEES SUMMIT, MO 64082
Inspected On: Wednesday, March 17, 2021
Inspected By: John Morris
Expiration Date: 3/24/2021 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	John Morris	Temporary C of O	Wednesday, March 17, 2021

Corrective Action Required:

1	Misc	-Irrigation permit required -Downspouts to discharge minimum 36 inches from foundation
---	------	---

TCO EXTENDED 7 DAYS VALID THROUGH 03/24/2021