

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203821
Address: 1541 SW MANOR LAKE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	Patrick Schonfeldt	Failed	Wednesday, March 17, 2021

Corrective Action Required:

1	Misc	-FIRE CAULK PENETRATIONS THROUGH CEILING IN MECH CLOSET -DEFECTIVE GFCI RECEPTACLES IN KITCHEN
---	------	---

Comments: