

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20193373
Address: 4064 NE TIMBERLAKE CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, March 18, 2021

Corrective Action Required:

1 Misc

FRAMING:

-Fb wall from I beam soffit ; fb space at basement bathroom shower from joist space

ELECTRICAL:

-Complete electrical throughout
**Secure wiring within 12" of panel

**OK TO INSULATE

Comments: