

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203513
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water Line - Construction Inspection	Joe Starlin	Passed	Friday, March 19, 2021

Informational:

1	Misc	2-5-21 3:30pm They are laying approximately 70' of water line. They will be sending me pics. 2-22-21 2:37pm They installed approximately 100' of water line with kickers. I have all pics of fittings and pipe and kickers. 2-25-21 2:15pm They have ran the water line up to the pad site. 3-19-21 3:22pm We are chlorinating approximately 90' of water line. 3:31pm The line is chlorinated.
---	------	--

Comments: