

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201148
Address: 1610 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Tuesday, March 16, 2021

Corrective Action Required:

1	Misc	-Final grade and sod -Provide gutters, downspouts, splash blocks, and sump discharge extension -GFCI at front door doesn't reset -Provide non combustible attic access cover -Provide handrail for garage entry stairs over 4 rises -Provide GFCI protection at dishwasher and washing machine -Provide Hammer arrestors at kitchen sink and washing machine -Provide (2) 3" security screws per hinge and strike plate at exterior doors -Secure whip at AC -Lower drain to grade inside of window well
---	------	---

Comments: