

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210333

Address: 2050 NW LOWENSTEIN DR, Unit:E, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Partial	Monday, March 22, 2021

Corrective Action Required:

1	Misc	- OK TO ROCK EXTERIOR WALLS - - Ok to rock wall at hood near rear door - : RESTROOMS : - PROVIDE BOCA PLATES DWV AT BOTTOM PLATE - - SUPPORT VERTICAL DWV 2" & SMALLER AT MIDPOINT -
---	------	--

Comments: