

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRPR20211232  
Address: 1912 NE CATALINA AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Final Mechanical Inspection - Commercial</b>	Khanh Nguyen	Passed	Monday, March 22, 2021

Informational:  
1

THIS IS A REDO OF UNDERSLAB BUILDING DRAIN. THE SLOPE OF THE BUILDING DRAIN IS COMPLIANT PER CODE, WITH MIN 1/8" PER FT OF SLOPE THROUGHOUT ITS LENGTH.

**Comments:**