


BOB D. CAMPBELL & CO.
Structural Engineers Since 1957
4338 Belleview Ave. 816.531.4144
Kansas City, MO 64111 www.bdc-engrs.com

PRINCIPALS

President
Michael J. Falbe, P.E.

Richard C. Crabtree, P.E.
Wayne E. Davis, P.E.
Jeffrey L. Wright, P.E.
Christopher W. Boos, P.E.
Clark A. Basinger, P.E.
Brandon M. Ford, P.E.
Christopher A. Beverlin, P.E.

Administrative Manager
Paul M. Spena

March 19, 2021

Mr. Bradley Peterson
Bradley Collins LLC

Re: Summit at West Pryor Area E Retail #4
Structural Loading Review.

Dear Bradley:

We have reviewed the structural for the ability to support the planned MEP loads and find that it has the required strength and stiffness to resist these forces without the needs for reinforcement. Equipment and ductworks should be hung from the steel beams.

Please call if you have any questions or if we may be of further service.

Sincerely,

BOB D. CAMPBELL & CO.
Structural Engineers



Clark A. Basinger, P.E., Principal

cc: File / TRI1802

