

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204543
Address: 103 NW GRADY CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, March 23, 2021

Corrective Action Required:

1	Misc	- EROSION CONTROL FAILED 3/18/21 - - MAINTAIN SILT FENCE - - ROUGH IN INSPECTION DENIED -
---	------	---

Comments: