



March 23, 2021

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

**RE: Field Issue of support posts for front porch roof not landing on foundation wall for Lot # 6 Hawthorne Ridge
– 2926 SW Arboridge Dr. Lee's Summit, MO 64082 – Permit # PRRES20203936**

This letter addresses the front porch posts for roof support not landing on foundation wall for Lot #6 Hawthorne Ridge.

- Temporarily support front porch roof with (3) #2 2x4 Douglas Fir Larch #2 studs on each side of post.
- Remove posts and pour front porch slab per plans.
- Once front porch slab has reached sufficient strength at a minimum of 7 days from pour, replace posts to bear onto slab.

Sincerely,

A handwritten signature in blue ink, appearing to read "Bradley Huxol".

Bradley Huxol, PE

