

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20200845

Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086
100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Robb Popp	Partial	Wednesday, March 24, 2021

Corrective Action Required:

1 THE FOLLOWING AREAS ARE APPROVED

THE FOLLOWING AREAS ARE APPROVED TO COVER:

ROOMS-, 49,60,61
ROOM 77A,77B-
ROOMS 110A,111A,112A,113A,114A,115A,116A,117A,118A;
PATIENT ROOMS 110-118, 81,83,85,87,89,91,93,95,96,98,100,102,104,106
HARD LIDS UNIT BATHROOMS-081A, 083A, 085A, 087A, 089A, 091A, 093A, 095A, 096A, 098A, 100A, 102A, 104A, 106A,
WORK STATION 1B099,1B135, 1B119
HARD LIDS AT: NOURISH 1B133, STRETCHER/ EQUIPT STORAGE 1B120
NURSE'S STATION 1B088 SOFFITS
BREAK ROOM 068
FAST TRACK 069, 071, 072, 073
TRAUMA 109
CORRIDORS 1B00N, 1B00P TO JUST PAST ROOM 106, 1B136, 1B00O, 1B00M,

EMERGENCY:
TOILETS 1B001, 1B002, 1B009
TRIAGE 1B003, 1B004, 1B005
CORRIDOR B102 TO LINE BC

WAITING 1B00C TO LINE BC.6
RECEPTION 1B007
CONSULT 1B008

HARD LIDS IN PATIENT BATHROOMS:163-166A, 152-154
SOFFIT AT NURSE STATION 158

Corrective Action Required:

2 Misc

Comments: