

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204555  
Address: 1817 SW MERRYMAN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Wednesday, March 24, 2021

Informational:	
1      Misc	-OK TO COVER PORCH AND COVERED DECK

Corrective Action Required:	
2      Miscellaneous Correction	-PORTAL FRAMING REQUIRES 3" NAILING PATTERN ON ALL STUDS AND 16D NAILS FROM TOP PLATE TO HEADER 3" OC

**Comments:**