CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203936

Address: 2926 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

All Rough Inspection - Robb Popp Failed Wednesday, March 24,

Residential 2021

Corrective Action Required:

1 Misc -(4) 2x4 stud pack at all girder truss bearing ends per plans-bed 1 and corner

of bed 1/ great room

-Support steel/flex gas line run through basement rec room -(2) bolts at each post/beam connection at deck per code

-bolt outer ply of rim to ledger and add angel clips on inner ply

-Nail exterior sheathing 6" edge 12" field

-Front covered porch columns not supported by foundation wall

Comments: