



March 24, 2021

Summit Homes  
120 SE 30<sup>th</sup> St.  
Lee's Summit, MO 64082

**RE: Field Issue of support posts for front porch roof not landing on foundation wall for Lot # 6 Hawthorne Ridge – 2926 SW Arboridge Dr. Lee's Summit, MO 64082 – Permit # PRRES20203936**

This letter addresses the front porch posts for roof support not landing on foundation wall for Lot #6 Hawthorne Ridge.

- Posts shall be supported temporarily on grade in order to pour slab.
- Front porch slab shall be poured per plans.
- Once front porch slab has reached sufficient strength at a minimum of 7 days from pour, replace posts to bear onto slab.

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Huxol", is written over a light blue horizontal line.

Bradley Huxol, PE

