

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203513
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
-------------	------------	----------	-------

Water Line - Coliform Test 1	Joe Starlin	Pending	
-------------------------------------	-------------	---------	--

Informational:

1	Misc	3-23-21 Pro Design Construction is on site and we will be pulling the first water sample. We pulled the sample at 9:37am in a light wind. The sample is on ice and I will be taking it to the lab. 11:30am I have dropped the water sample off at the lab.
---	------	--

Corrective Action Required:

2	Misc	3-25-218:21AM Keystone Lab has sent A email saying sample 1 has passed. I attached the results to Documents and Images.
---	------	---

Comments: