

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203428
Address: 4405 SW TANZANITE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Thursday, March 25, 2021

Corrective Action Required:

1	Misc	-Final grade and sod -splash blocks and sump pump discharge extension required -seal all penetrations in siding, seal along top of AC disconnect and meter can -Guardrail required at front porch, more than 30" from grade -Tempered glass required at window in master bath shower "replace light fixtures, attic access covers, switch and outlet covers removed in garage for painters"
---	------	--

Comments: