

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202812
Address: 3209 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Morris	Not Ready	Thursday, March 25, 2021

Corrective Action Required:

1	Misc	-fireblock penetrations in wood fireblock, second story concealed space electrical & HVAC lineset penetrations
		-DECK-
		-Beam/post connections per code

Comments: