

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203936
Address: 2926 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Thursday, March 25, 2021

Corrective Action Required:

1	Misc	-Nail exterior sheathing 6" edge 12" field -Front covered porch columns not supported by foundation wall - eng letter received, columns supported by 2x4 per letter, reschedule inspection post porch pour per engineer letter
---	------	---

****OK FOR INSULATION AND ROCK****

Comments: