

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20203513  
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
-------------	------------	----------	-------

<b>Water Line - Coliform Test 2</b>	Joe Starlin	Pending	
-------------------------------------	-------------	---------	--

Informational:

1	Misc	3-24-21 9:25am 46 degrees with a overcast and damp out. Pro Design pulled the second water sample. I will take it to the lab for testing. 10:14am I dropped off the sample at lab.
---	------	--

Corrective Action Required:

2	Misc	3-26-21 7:05am The second water sample has passed and the document has been attached to Documents and Images.
---	------	---

**Comments:**