

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203284
Address: 4417 SW NAUTILUS PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Monday, March 29, 2021

Corrective Action Required:

1	Misc	- (4) stud pack at all girder truss support ends per plans - All truss hangers per plans - Truss bracing per plans (approved truss details not on site, unable to determine at inspection) - Complete electrical at suspended slab in basement - Fireblock between top plate and framing/foundation wall in basement - see E wall basement bedroom at gas line
---	------	--

Comments: