CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20201466

Address: 4060 NE RALPH POWELL RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Sanitary Sewer - Vacuum Ronald Paynter Passed Monday, March 29,

2021

Informational:

1 Misc 3/24/21 Wednesday

Vacuum test passed for MH A-1 & A-2

Corrective Action Required:

2 Misc All manholes except for B2 passed their vacuum test. Beemer will be back on

Monday to remove casting, cone and rings to find the leak. RP 3-26-21

Informational:

3 Misc Sanitary manhole B2 passed it's vacuum test. RP 3-29-21

Comments: