

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202276
Address: 4712 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, March 30, 2021

Corrective Action Required:

1	Misc	FRAMING & ETC: -Provide flashing above window trim -Shim gaps at bottom of garage studs -Seams at the garage PFH walls must be within 24" of the mid-wall height, not near the bottom -Provide R-13 insulation at garage/closet return air wall -fb wall from fur down ceiling space
---	------	---

****OK TO INSULATE**

Comments: