

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202213
Address: 3221 SW MARY ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Ronald Paynter	Partial	Tuesday, March 30, 2021

Informational:

1 Misc

Forms were placed and aggregate was present, but still needs to compacted. Also needs to remove piping underneath the sidewalk. Talked with Tim about those issues along with sidewalk finish and cure requirements. RP 3-30-21

Comments: