

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20203885  
Address: 417 SE MILL CREEK CIR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Final Building Inspection - Residential</b>	Robb Popp	Failed	Tuesday, March 30, 2021

Corrective Action Required:

1	Miscellaneous Correction	Provide AFCI protection on branch circuits per E3902.16
---	--------------------------	---

**Comments:**