

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210630
Address: 2052 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Residential	Michael Harkins	Failed	Tuesday, March 30, 2021

Corrective Action Required:

1	Misc	- PROVIDE (2) #4 BARS CONTINUOUS PER PLAN OR PROVIDE HELIX OPTION DETAIL -
---	------	---

Comments: