

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203433
Address: 1721 NE WOODLAND SHORES CT, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Residential	Robb Popp	Failed	Wednesday, March 31, 2021

Partial Correction:

1 Misc

POOL COMPONENTS BONDED: POOL SHELL WITH JUMPERS TO BOND PERIMETER, PERIMETER BOND, JUMPER TO EQUIPMENT PAD

****NOT READY. PROVIDE BONDING JUMPER FROM DEVICE IN SKIMMER TO PERIMETER BONDING AND CONNECT WITH LISTED CLAMP-DEVICE IS CURRENTLY NOT CONNECTED TO REST OF BONDING**

Comments: